



Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam,
Khand Karyalay, Varanasi , Pin 221007

* TEST REPORT *

Name & Address Of Customer:		Customer Reference No.	No:143/VNS/27 Dated: 05/05/2026			
R.S.CONVENT SAINIK SCHOOL & HOSTEL (10+2) LEDHUPUR, ASHAPUR, VARANASI		Sample Submitted by	GAURAV RAI			
		Date of Sample Receipt	08-05-2026			
		Analysis Starting Date	08-05-2026			
		Analysis completion Date	10-05-2026			
Discipline: Chemical Testing		Group:				
Test Report No.:	RWTL/VNS/26-27/05	Date of Issue :	10-05-2026			
Registration no.:	RWTL/VNS/26-27/128	Condition of Sample:	Unsealed			
Source:	Na	Quantity/Type of Bottle:	1000ml/ Amber Colored Glass Bottle			
Scheme:	Na	Location/Depth:	R.O.Plant R.S.Convent Sainik School Ledhupur, Ashapur, Varanasi			
Village:	Ledhupur	Habitation:	NA			
Block:-	Chiraigaon	Districts	VARANASI			
Latitude:		Longitude:	NA			
Sample Type: Treated Water						
Sr.No.	Parameter	Result	As per 15-10500:2012(2nd Rev.)		Unit	Reference Method
			Acceptable Limit	Permissible Limit		
1	pFI	7.75	6.5-8.5	No Relaxation		IS 3025(Part 11-1993)Electrometric Method
2	Colour	1	5	15	Hazen	IS3025(Part 4-2021)Visual Comparison method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5-2018) (Second Revision)
4	TDS	280	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	I633025 (Pan21-2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	mS/l	APHA (23rd Ed.2017) Method:3500-Mg+2 B By Caculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be Destroyed after retention time unless otherwise specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS= Total Dissolved Solids, mg/l=Milligram per Liter, BDL= Below Detection limit, APHA=American Public Health Associatin , IS= India Standard, NT= Not Tested ,Not Applicable NTU = Nephelometric turbidity Unit , RA Reaffirmed)
5. "Value not available or test not performed for this parameter

Ram Awatar
Quality Manager
Authorized Signatory
For, Office of Executive Engineer
U.P Jal Nigam Varanasi ,

सहायक अभियन्ता
उत्तर प्रदेश जल निगम
वाराणसी

.....End of the Test Report.....

Principal
R.S. Convent Sainik School
Ledhupur, Ashapur, Varanasi

Chairman
R.S. Convent Sainik School
Ledhupur, Ashapur, Varanasi

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CCERTIFICATE

No. C1/143/VNS/27Dated: 5-5-26

It is certified that an inspection team headed by Dr. Ram Awatar
 (Name of officers with designation) from C1 JALKAL DEPT VARANASI PHED
 Inspected the R.S. Convent Sainik School, Ledhupur, Ashapur, VNS
 (Name & Address of the school) on 8-5-26 (date of inspection) and on the basis of
 Water Test Report (Attached) bearing no. R.WTL/VNS/2026-27/143 Dated 8-5-26
 of JAL NIGAM VARANASI (PHED Lab) certified that
 the R.S. Convent Sainik School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution. school is also maintains the
 hygienic sanitation condition in the school building & the campus as per norms prescribed by the
 Central / State / U.T. Govt.

This certificate is valid till One yearSignature with Seal: Ram AwatarName: Ram AwatarDesignation: C1 PHED JALKAL VARANASI

Name & Address of the office/Department.

To
R.S. Convent Sainik School
Ledhupur, Ashapur, Varanasi
 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized office / PHED Lab / local bodies

Angh.
 PRINCIPAL
 R.S. Convent Sainik School
 Ledhupur, Ashapur, Varanasi

Chairman
 R.S. Convent Sainik School
 Ledhupur, Ashapur, Varanasi